

Fairwinds # 2 - Well Data - Depth 200 ft / 70 m

2000	Average Capacity (m ³ /min)	Discharge pressure (psi)	Static level (ft)	Static level (m)	Pumping level (ft)	Pumping Level (m)	Drawdown (m)	Meter reading (m ³)	Monthly Consumption (m ³)	Hour Meter	Total Hours
Jan-00	0.443			0.00		0.00	0.00		1815		68.3
Feb-00	0.443			0.00		0.00	0.00		2687		101.1
Mar-00	0.443			0.00		0.00	0.00		3112		117.1
Apr-00	0.443			0.00		0.00	0.00		4388		165.1
May-00	0.443			0.00		0.00	0.00		4170		156.9
Jun-00	0.443			0.00		0.00	0.00		5951		223.9
Jul-00	0.443			0.00		0.00	0.00		9377		352.8
Aug-00	0.443			0.00		0.00	0.00		8396		315.9
Sep-00	0.443		140	42.67	158	48.16	5.49	35390	6857	17779.2	258
Oct-00	0.468		145	44.20	160	48.77	4.57	42990	7600	18050.1	270.9
Nov-00	0.471		140	42.67	161	49.07	6.40	47856	4866	18222.3	172.2
Dec-00	0.472		140	42.67	153	46.63	3.96	51862	4006	18363.9	141.6
Jan-01	n/a	n/a	n/a	n/a	n/a	n/a	n/a		n/a		n/a

Well Data Summary

Static Level	
Minimum	0.00
Maximum	44.20
Average	14.35

Pumping Level	
Minimum	0.00
Maximum	49.07
Average	16.05

Drawdown	
Minimum	0.00
Maximum	6.40
Average	1.70

Consumption	
Minimum	1815
Maximum	9377
Average	5268.8
Total	63225

Total Hours	
Minimum	68.3
Maximum	352.8
Average	195.3
Total	2343.8

