

Nanoose # 2 - Well Data - Depth - 152 ft / 46.3 m

2004	Average Capacity (m ³ /min)	Discharge pressure (psi)	Static level (ft)	Static level (m)	Pumping level (ft)	Pumping Level (m)	Drawdown n (m)	Meter reading (gal)	Monthly Consumption (m ³)	Hour Meter	Total Hours	Water over pump			
												Level (m)	Level Low	Level Critical	
Jan-04	0.478	86	135	41.15	144	43.89	2.74	43335300	4598.28	20864.1	160.2	2.41	no	no	
Feb-04	0.479	82	135	41.15	143	43.59	2.44	44346800	3860.46	21024.3	134.3	2.71	no	no	
Mar-04	0.482	88	135	41.15	143	43.59	2.44	45196000	5256.99	21158.6	181.6	2.71	no	no	
Apr-04	0.485	86	135	41.15	143.5	43.74	2.59	46352400	6422.59	21340.2	220.7	2.56	no	no	
May-04	0.490	84	135.5	41.30	143.5	43.74	2.44	47765200	11291.81	21560.9	383.9	2.56	no	no	
Jun-04	0.491	86	137	41.76	145.5	44.35	2.59	50249100	13212.04	21944.8	448.6	1.95	yes	no	
Jul-04	0.490	84	138	42.06	148	45.11	3.05	53155400	16355.60	22393.4	555.8	1.19	yes	no	
Aug-04	0.460	88	139	42.37	152	46.33	3.96	56753200	13062.02	22949.2	473.7	-0.03	yes	yes	
Sep-04	0.419	90	138	42.06	147	44.81	2.74	59626500	6072.55	23422.9	241.8	1.49	yes	no	
Oct-04	0.420	94	136	41.45	145	44.20	2.74	60962300	4448.72	23664.7	176.6	2.10	no	no	
Nov-04	0.420	90	136	41.45	144	43.89	2.44	61940900	3840.01	23841.3	152.3	2.41	no	no	
Dec-04	0.422	92	136	41.45	143.5	43.74	2.29	62785600	3798.64	23993.6	150.2	2.56	no	no	
Jan-05	n/a	n/a	n/a	n/a	n/a	n/a	n/a	63621200	n/a	24143.8	n/a				
Ave. Cap.	0.461														

Well Data Summary

Static Level	
Minimum	41.15
Maximum	42.37
Average	41.54

Pumping Level	
Minimum	43.59
Maximum	46.33
Average	44.25

Drawdown	
Minimum	2.29
Maximum	3.96
Average	2.71

Consumption	
Minimum	3798.6376
Maximum	16355.5988
Average	7685.0
Total	92219.7014

Total Hours	
Minimum	134.3
Maximum	555.8
Average	273.3
Total	3279.7

